

East North Interconnection Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of AUGUST 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of AUGUST 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time Prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

East North Interconnection Company Limited

I. AC Transmission Line Outage Details for the month of AUGUST 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	03-08-2024 09:19	04-08-2024 20:10	0:00:00	0:00:00	0:00:00	34:51:00	As per ERLDC instruction the line was taken out due to Voltage regulation.	100.00%
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	23-08-2024 09:03	23-08-2024 21:57	0:00:00	0:00:00	0:00:00	12:54:00	PGCIL taken the Line outage for New RTU Augmentation(ERLDC)-CT wiring, MFT installation and Control Panel modification, New Cable laying from CR Panels to New RTU Panel. Only Line portion is under the Jurisdiction of ENICL.	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 2(ALIP- SLG #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages for the month of August 24	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 2(BNG- ALIP #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages for the month of August 24	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 1(ALIP- SLG #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages for the month of August 24	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 1(BNG- ALIP #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages for the month of August 24	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2(NPRN- BSF# 2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages for the month of August 24	