

East North Interconnection Company Limited

I. AC Transmission Line Outage Details for the month of JUNE 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	03-06-2024 15:54	04-06-2024 07:30	15:36:00	0:00:00	0:00:00	0:00:00	Line tripped due to R-phase to Earth fault due to conductor snapping. Rectification work was extended due to severe Right of Way (ROW) issues at the site. Despite ENICL's best efforts, the team encountered significant challenges related to administrative support, primarily due to the ongoing declaration of election results. The unavailability of key administrative personnel such as the District Magistrate (DM), Sub-Divisional Magistrate (SDM), and Superintendent of Police (SP) has hindered our progress, preventing from resolving the ROW issues promptly. Email communication and FIR attached for your reference. Request to consider this period under 'LMAC' category as it was beyond the control of the Licensee.	98.83%
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	04-06-2024 07:30	10-06-2024 17:30	0:00:00	154:00:00	0:00:00	0:00:00	Line tripped due to R-phase to Earth fault due to conductor snapping. Rectification work was extended due to severe Right of Way (ROW) issues at the site. Despite ENICL's best efforts, the team encountered significant challenges related to administrative support, primarily due to the ongoing declaration of election results. The unavailability of key administrative personnel such as the District Magistrate (DM), Sub-Divisional Magistrate (SDM), and Superintendent of Police (SP) has hindered our progress, preventing from resolving the ROW issues promptly. Email communication and FIR attached for your reference. Request to consider this period under 'LMAC' category as it was beyond the control of the Licensee.	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	10-06-2024	11-06-2024	10:05:00	0:00:00	0:00:00	0:00:00	1.Charging clearance given to RLDC at 03:35 Hrs. 2.Code received at 04:04 Hrs. 3.Charging code conveyed to RTAMC ER1 at 04:09. 4.Line charged at 06:04 Hrs. (Delay due to unknown reason) Email communication attached for your reference. Request to consider this period under 'Others' category as it was beyond the control of the Licensee.	
400 kv (Quad ) D/C Alipurduar - Siliguri line CKT- 1(ALIP- SLG #1)	11-06-2024	11-06-2024	0:00:00	2:29:00	0:00:00	0:00:00	Shutdown availed by RTAMC-ER-II for wiring adaption work at Binaguri SS under RTU replacement/SAS upgradation project. Only line portion is under the ownership of ENICL.	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2( NPRN- BSF# 2)	14-06-2024	14-06-2024	0:00:00	0:00:00	0:00:00	9:19:00	Shutdown availed by ER1 For RTU upgradation work. Only line portion is under the ownership of ENICL.	
400 kv (Quad ) D/C Bongaigaon - Alipurduar line CKT- 2(BNG- ALIP #2)	15-06-2024	15-06-2024	0:00:00	0:00:00	0:00:00	11:29:00	No Tripping/Outages in this line for the month of Jun24	
400 kv (Quad ) D/C Alipurduar - Siliguri line CKT- 2(ALIP- SLG #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of Jun24	

**East North Interconnection Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JUNE 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of JUNE 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time Prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil