

East North Interconnection Company Limited

I. AC Transmission Line Outage Details for the month of MAY 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 2(BNG- ALIP #2)	27-05-2024 21:33	28-05-2024 03:52	6:19:00	0:00:00	0:00:00	0:00:00	Line Tripped on transient R-phase to B-phase due to heavy rain fall & thunderstorm at fault location. The fault location is within the path of Cyclone "Remal," as per the advisory issued by NERLDC. The transient Ph-to-Ph fault that occurred is generally attributed to weather-related conditions which is beyond the control of licensee. This is for the information that the said line is double circuit line and Ph to Ph fault was generally happened due to transient nature of fault. Charging clearance was given at 02:56Hrs on 28.05.2024 and charging code for the same received at 03:42Hrs and line was finally charged at 03:52Hrs.	100.00%
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 1(ALIP- SLG #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May24	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 2(ALIP- SLG #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May24	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 1(BNG- ALIP #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May24	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT- 1 (NPRN-BSP#1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May24	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT- 2(NPRN- BSP# 2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May24	

East North Interconnection Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time	Actual restoration time	
			(in days)	(in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil