

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of APRIL 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400kV D/C LILO POINT (T. No. - 130) - Sundargarh	4-20-24 3:19 PM	4-20-24 4:54 PM	0:00:00	1:35:00	0:00:00	0:00:00	400KV IBUEL (Ind Barath Energy Utikal ltd) - Sundargarh Line - 1 tripped from Sundargarh end and idle charged from IBUEL end at 15:29Hrs due malfunction of PLCC panel at IBUEL end by which DT received at Sundargarh end. ONLY Line Portion Belongs to OGPTL.	100.000%
400kV D/C OPGC-LILO POINT (T. No. - 130)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of April-24	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of April-24	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of April-24	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of April-24	

