

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of AUGUST 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	10-08-2024 14:06	01-09-2024 00:00	0:00:00	0:00:00	0:00:00	513:54:00	Line hand tripped as per RLDC instructions for to voltage regulation	99.900%
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	20-08-2024 03:12	20-08-2024 05:26	0:00:00	0:00:00	2:14:00	0:00:00	Line tripped from OPGC end & was in Idle charge condition from IBEUL end due to transient R-phase to earth fault. Request to consider this outage under 'Others' category as only the line portion is under the ownership of OGPTEL.	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	22-08-2024 01:46	22-08-2024 03:22	1:36:00	0:00:00	0:00:00	0:00:00	IBEUL taken the Emergency shutdown was for attending the hotspot of metering CT at IBEUL end. Request to consider this outage under 'Others' category as only the line portion is under the ownership of OGPTEL.	
400kV D/C OPGC-LILO POINT (T. No. - 130)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of AUGUST - 24	
400kV D/C LLO POINT (T. No. - 130) - Sundargarh			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of AUGUST - 24	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of AUGUST - 24	

