Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of JULY 2024

| | Outage | Restoration | Duration of Outage Attributable to | | | 0 | Reason of | % |
|---|------------------|------------------|---|---------|--|------------------|---|--------------|
| Element Name | Date & Time | Date & Time | Inter-State Transmission Licensee | Others | System constraint/ Natural calamity/ Militancy | Deemed Available | Outage | Availability |
| | | | Hrs:Min | Hrs:Min | Hrs:Min | Hrs:Min | | |
| 765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2 | 01-07-2024 17:08 | 14-07-2024 18:36 | 0:00:00 | 0:00:00 | 0:00:00 | 313:28:00 | Line hand tripped as per RLDC instructions for to voltage regulation | |
| 400kV D/C OPGC-LILO POINT (T. No 130) | 13-07-2024 20:43 | 13-07-2024 21:39 | 0:00:00 | 0:56:00 | 0:00:00 | 0:00:00 | Line tripped from OPGC end & was in Idle charge condition from IBEUL end due to transient R-phase to earth fault. Request to consider this outage under 'Others' category as only the line portion is under the ownership of OGPTL. | |
| 400kV D/C LILO POINT (T. No 130) - Sundargarh | 20-07-2024 13:19 | 20-07-2024 16:53 | 0:00:00 | 0:00:00 | 0:00:00 | 3:34:00 | IBEUL taken the Emergency shutdown was for attending the hotspot of metering CT at IBEUL end. Request to consider this outage under 'Others' category as only the line portion is under the ownership of OGPTL. | 100.000% |
| 400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1 | | | 0:00:00 | 0:00:00 | 0:00:00 | 0:00:00 | NO Tripping/Outages in this line for the month of July - 24 | |
| 765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1 | | | 0:00:00 | 0:00:00 | 0:00:00 | 0:00:00 | NO Tripping/Outages in this line for the month of July - 24 | |

Schedule I

Odisha Generation Phase-II Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JULY 2024

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|--------------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |
| Nil | Nil | Nil |

Sl. No. Voltage Level Name of Line COD Line Length (No.of sub cor Weightage Factor

III. Details of compensation paid by the inter-State transmission licensee for the month of JULY 2024

| Element Name | Violation o | f Regulation | Violation of F | | |
|--------------|-------------------------|--------------------------|------------------|--------------------|---------------------------|
| | % | | Restoration time | Actual restoration | |
| | Availability prescribed | Actual % Availability | prescribed | time | Compensation paid (in Rs) |
| | | | (in days) | (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| | Nil | | | | |

Schedule II

Schedule III

(N: