

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of MAY 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	11-05-2024 17:05	11-05-2024 22:12	0:00:00	0:00:00	5:07:00	0:00:00	Line tripped on R-phase to Y-phase to Fault due to inclement weather condition and lightning at fault location. Enclosed here with the Newspaper Cutting and the photograph of white spot found on cross arm. The transient Ph-to-Ph fault that occurred is generally attributed to weather-related conditions which is beyond the control of licensee. This is for the information that the said line is double circuit line and Ph to Ph fault was generally happened due to transient nature of fault. Charging clearance was given at 21:24Hrs and charging code for the same received at 21:41Hrs and line was finally charged at 22:12Hrs.	100.000%
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	15-05-2024 19:48	15-05-2024 21:12	0:00:00	0:00:00	1:24:00	0:00:00	Line Tripped due to R-phase to Earth Fault. Charging clearance was given at 21:12Hrs and charging code for the same received at 21:40Hrs and line was finally charged at 22:33Hrs.	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	15-05-2024 21:12	15-05-2024 22:33	0:00:00	1:21:00	0:00:00	0:00:00	Charging clearance was given at 21:12Hrs and charging code for the same received at 21:40Hrs and line was finally charged at 22:33Hrs. Kindly consider the additional outage period under others account. Enclosed here with the email communication for the same.	
400kV D/C LILO POINT (T. No. - 130) - Sundargarh			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May-24	
400kV D/C OPGC-LILO POINT (T. No. - 130)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May-24	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May-24	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line for the month of May-24	

Odisha Generation Phase-II Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

Sl. No. Voltage Level Name of Line COD Line Length (+No.of sub cor Weightage Factor (N:

III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil