

Purulia & Kharagpur Transmission Company Limited
1. AC Transmission Line Outage Details for the month of JULY 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kV Chaibasa-Kharagpur D/C line CKT- 1	29-07-2024 10:50	29-07-2024 19:17	0:00:00	0:00:00	0:00:00	8:27:00	PGCIL taken the emergency shutdown for attending the hotspot in line isolator at Chaibasa end. Only line portion falls under the jurisdiction of PKTCL.	100.000%
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00:00	0:00:00	0:00:00	0:00:00	No Trippings/ Outage in this line for the month of July - 24	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1			0:00:00	0:00:00	0:00:00	0:00:00	No Trippings/ Outage in this line for the month of July - 24	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2			0:00:00	0:00:00	0:00:00	0:00:00	No Trippings/ Outage in this line for the month of July - 24	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JULY 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JULY 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil