

Purulia & Kharagpur Transmission Company Limited
 I. AC Transmission Line Outage Details for the month of MAY 2024

Schedule I

| Element Name | Outage | Restoration | Duration of Outage Attributable to | | | | Reason of | % |
|---|------------------|------------------|--|-------------------|---|-----------------------------|--|--------------|
| | Date & Time | Date & Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | Outage | Availability |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-2 | 18-05-2024 06:07 | 18-05-2024 07:15 | 0:00:00 | 1:08:00 | 0:00:00 | 0:00:00 | PKTCL taken the shutdown for Insulator replacement work which was identified through PID testing, to enhance system reliability and security. Shutdown was taken at 06:07 hrs and Earth Switch closing confirmation for the same was received at 07:15hrs from PPSP End. Request to consider this period under 'Others' Category as this delay was beyond the control of the licensee, as only the line portion belongs to PKTCL. Enclosed here with email communication for your reference. | 99.214% |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-2 | 5-18-24 7:15 AM | 5-18-24 1:25 PM | 6:10:00 | 0:00:00 | 0:00:00 | 0:00:00 | PTW for the shutdown was received at 07:15Hrs and PKTCL given the charging clearance at 13:18Hrs and charging code for the same was received at 13:25Hrs and line was finally charged at 14:11Hrs. Delayed in charging after receipt of charging code was due to unknown reason. Enclosed here with the email communication. | |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-2 | 18-05-2024 13:25 | 18-05-2024 14:11 | 0:00:00 | 0:46:00 | 0:00:00 | 0:00:00 | PKTCL given the charging clearance at 13:18Hrs and charging code for the same was received at 13:25Hrs and line was finally charged at 14:11Hrs. Delayed in charging after receipt of charging code was due to unknown reason. Request to consider this period under 'Others' Category as this delay was beyond the control of the licensee, as only the line portion belongs to PKTCL. Enclosed here with the email communication for your reference. | |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-1 | 19-05-2024 06:34 | 19-05-2024 14:09 | 7:35:00 | 0:00:00 | 0:00:00 | 0:00:00 | PKTCL taken the shutdown for Insulator replacement work which was identified through PID testing, to enhance system reliability and security. | |
| 400 kV Chaibasa-Kharagpur D/C line CKT- 1 | 21-05-2024 08:01 | 21-05-2024 12:02 | 4:01:00 | 0:00:00 | 0:00:00 | 0:00:00 | PKTCL taken the shutdown for Insulator replacement work which was identified through PID testing, to enhance system reliability and security. Charging clearance was given at 11:59Hrs and charging code was received at 12:02 and line was finally charged at 13:06 delayed due to unknown reason. Enclosed here with the email communication. | |
| 400 kV Chaibasa-Kharagpur D/C line CKT- 1 | 21-05-2024 12:02 | 21-05-2024 13:06 | 0:00:00 | 1:04:00 | 0:00:00 | 0:00:00 | Charging clearance was given at 11:59Hrs and charging code was received at 12:02 and line was finally charged at 13:06 delayed due to unknown reason. Request to consider this period under 'Others' Category as this delay was beyond the control of the licensee, as only the line portion belongs to PKTCL. Enclosed here with the email communication for your reference. | |
| 400 kV Chaibasa-Kharagpur D/C line CKT- 2 | 22-05-2024 07:48 | 22-05-2024 14:01 | 6:13:00 | 0:00:00 | 0:00:00 | 0:00:00 | PKTCL taken the shutdown for Insulator replacement work which was identified through PID testing, to enhance system reliability and security. Shutdown was taken at 07:48 hrs and Earth Switch closing confirmation for the same was received at 08:41hrs from RTAMC End. Charging clearance was given at 12:56Hrs and charging code of the same was received at 13:12Hrs and line was finally charged at 14:01Hrs. | |

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2024

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |
| Nil | Nil | Nil |

III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2024

Schedule III

| Element Name | Violation of Regulation | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|---------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |