

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of April 2024

Schedule I

Element Name	Outage Date Time	Restoration Date Time	Duration of Outage Attributable to				Reason of Outage	% Availability
			Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	04-04-2024 09:10	04-04-2024 15:16	06:06	00:00	00:00	00:00	Shutdown availed for AMP work.	99.8735%
400/220kV 500 MVA ICT-1 at SOHNA ROAD(GPTL)	08-04-2024 08:22	08-04-2024 19:23	11:01	00:00	00:00	00:00	Shutdown availed for AMP work.	
400kV Kadarapur(GPTL) - Sohna Road(GPTL) Ckt-2	10-04-2024 19:34	10-04-2024 22:14	02:40	00:00	00:00	00:00	Line tripped due to maloperation of relay.	
400kV Kadarapur(GPTL) - Sohna Road(GPTL) Ckt-2	15-04-2024 13:08	15-04-2024 14:24	01:16	00:00	00:00	00:00	Line tripped due to maloperation of relay.	
400kV D/C Sohna Road(GPTL) - Gurgaon(PG) Ckt 2	22-04-2024 11:16	22-04-2024 17:13	05:57	00:00	00:00	00:00	Shutdown availed for AMP work.	
400kV Neemrana (PG) -Dhanodha (HVPNL) -2	01-04-2024 00:00	01-04-2024 10:57	00:00	00:00	00:00	10:57	Continuously in outage from previous month. Shutdown availed by HVPNL for 400 KV Mahindergarh(APL)-Dhanoda(HV) (ATIL) Ckt-1 as both the line is connected to Tie Bay at Dhanonda..	
400kV Neemrana (PG) -Dhanodha (HVPNL) -2	30-04-2024 12:05	30-04-2024 14:51	00:00	00:00	00:00	02:46	Shutdown availed by HVPNL to attend the hot Spot on Tie Bay isolator of 400kV Dhanonda-Mahendergarh Ckt -1 (Tie bay no.417) which is not under the ownership of the GPTL. As both Line connected through THE BAY Only as per the NRLDC instruction (Both lines main bay were under shutdown).	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	19-04-2024 09:49	21-04-2024 17:18	0:00:00	0:00:00	0:00:00	55:29:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	26-04-2024 09:44	26-04-2024 17:53	0:00:00	0:00:00	0:00:00	8:09:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	26-04-2024 09:54	26-04-2024 13:34	0:00:00	0:00:00	0:00:00	3:40:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	27-04-2024 09:34	27-04-2024 16:17	0:00:00	0:00:00	0:00:00	6:43:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	27-04-2024 09:37	27-04-2024 16:22	0:00:00	0:00:00	0:00:00	6:45:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	28-04-2024 09:47	28-04-2024 17:04	0:00:00	0:00:00	0:00:00	7:17:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	28-04-2024 09:49	28-04-2024 16:51	0:00:00	0:00:00	0:00:00	7:02:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	29-04-2024 09:28	01-05-2024 00:00	0:00:00	0:00:00	0:00:00	38:32:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	29-04-2024 09:34	29-04-2024 16:19	0:00:00	0:00:00	0:00:00	6:45:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	29-04-2024 09:37	29-04-2024 16:31	0:00:00	0:00:00	0:00:00	6:54:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil