

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of August 2024

Schedule I

Element Name	Outage Date Time	Restoration Date Time	Duration of Outage Attributable to				Reason of Outage	% Availability
			Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	03-08-2024 03:51	01-09-2024 00:00	692:09	00:00	00:00	00:00	Bus Reactor could not be charged due to differential protection operated at 03:51 Hrs on 03-08-2024 against code: NRLDC-323.	
400kV Neemrana (PG) -Dhanodha (HVPNL) -1	13-08-2024 11:53	13-08-2024 15:16	00:00	00:00	00:00	03:23	Shutdown availed by HVPNL to attend the hot point on R&Y - phase (89 A) tie isolator of 400kV Dhanonda-Mahendergarh Ckt -2 and Neemrana Ckt-1 (Tie Bay no.414) <b>Only Line portion under the ownership of GPTL.</b>	
400kV Neemrana (PG) -Dhanodha (HVPNL) -2	13-08-2024 16:36	13-08-2024 20:10	00:00	00:00	00:00	03:34	Shutdown availed by HVPNL to attend the hot point on R&Y - phase (89 B) tie isolator of 400kV Dhanonda-Mahendergarh Ckt -1 and Neemrana Ckt-2 (Tie bay no.417) <b>Only Line portion under the ownership of GPTL.</b>	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	02-08-2024 10:06	03-08-2024 03:53	00:00	00:00	00:00	17:47	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	02-08-2024 10:13	03-08-2024 03:57	00:00	00:00	00:00	17:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	02-08-2024 10:11	03-08-2024 03:51	00:00	00:00	00:00	17:40	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Could not be charged due to differential protection operated at 03:51 Hrs on 03-08-2024	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	03-08-2024 11:59	04-08-2024 03:56	00:00	00:00	00:00	15:57	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	03-08-2024 12:04	04-08-2024 18:33	00:00	00:00	00:00	30:29	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	08-08-2024 11:24	09-08-2024 02:37	00:00	00:00	00:00	15:13	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	08-08-2024 11:35	09-08-2024 02:40	00:00	00:00	00:00	15:05	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	09-08-2024 09:48	11-08-2024 16:18	00:00	00:00	00:00	54:30	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	09-08-2024 09:52	11-08-2024 16:37	00:00	00:00	00:00	54:45	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	12-08-2024 11:18	12-08-2024 21:14	00:00	00:00	00:00	09:56	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	12-08-2024 11:14	12-08-2024 21:07	00:00	00:00	00:00	09:53	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	13-08-2024 10:42	19-08-2024 18:30	00:00	00:00	00:00	151:48	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	13-08-2024 10:47	15-08-2024 04:51	00:00	00:00	00:00	42:04	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	16-08-2024 11:24	16-08-2024 22:20	00:00	00:00	00:00	10:56	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	17-08-2024 11:43	17-08-2024 21:11	00:00	00:00	00:00	09:28	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	20-08-2024 10:20	01-09-2024 00:00	00:00	00:00	00:00	277:40	Bus reactor taken out as per NRLDC instructions due to voltage regulation. <b>Still not charged in this month.</b>	

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of August 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	21-08-2024 09:57	21-08-2024 18:08	00:00	00:00	00:00	08:11	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	24-08-2024 09:56	01-09-2024 00:00	00:00	00:00	00:00	182:04	Bus reactor taken out as per NRLDC instructions due to voltage regulation. <b>Still not charged in this month.</b>	

**Gurgaon Palwal Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of August 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil