

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of July 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV D/C Sohna Road(GPTL) - Manesar(PG) Ckt-2	26-07-2024 12:59	26-07-2024 17:08	00:00	00:00	00:00	04:09	Shutdown availed by CPCC1 to attend Hotspot at Y phase Bottom wave trap.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	01-07-2024 00:00	01-08-2024 00:00	00:00	00:00	00:00	744:00	Continuously in outage from April'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	01-07-2024 11:46	03-07-2024 18:50	00:00	00:00	00:00	55:04	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	03-07-2024 10:03	03-07-2024 18:47	00:00	00:00	00:00	08:44	Continuously in outage from last month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	11-07-2024 12:09	31-07-2024 19:18	00:00	00:00	00:00	487:09	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	11-07-2024 10:40	31-07-2024 19:21	00:00	00:00	00:00	488:41	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil