

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of June 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Neemrana (PG) -Dhanodha (HVPNL) -1	06-06-2024 16:25	06-06-2024 22:35	00:00	00:00	00:00	06:10	Emergency shutdown availed by SLDC-HR for attending the hot point of R- phase of 89B and Y-Phase of 89A of Tie bay Isolator (414). Tie Bay under the ownership of HVPNL, accordingly the outage is not accountable to GPTL.	100.0000%
400kV Neemrana (PG) -Dhanodha (HVPNL) -1	17-06-2024 15:48	17-06-2024 17:37	00:00	00:00	01:49	00:00	As per the information received from PGCIL & HVPNL, Line tripped due to over voltage protection operated in grid.	
400kV D/C Sohna Road(GPTL) - Gurgaon(PG) Ckt 1	20-06-2024 18:57	20-06-2024 21:35	00:00	00:00	02:38	00:00	Line tripped due to Over Voltage operated at Gurgaon end and DT received at Sohna end.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	01-06-2024 00:00	01-07-2024 00:00	00:00	00:00	00:00	720:00	Continuously in outage from April'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	01-06-2024 00:00	28-06-2024 07:32	00:00	00:00	00:00	655:32	Continuously in outage from last month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	01-06-2024 00:00	28-06-2024 07:24	00:00	00:00	00:00	655:24	Continuously in outage from last month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of June 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil