

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2024

Schedule I

| Element Name | Outage | Restoration | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|--|------------------|------------------|------------------------------------|---------|--|------------------|---|----------------|
| | Date Time | Date Time | Inter-State Transmission Licensee | Others | System constraint/ Natural calamity/ Militancy | Deemed Available | | |
| | | | Hrs:Min | Hrs:Min | Hrs:Min | Hrs:Min | | |
| 400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL) | 01-05-2024 00:00 | 01-06-2024 00:00 | 00:00 | 00:00 | 00:00 | 744:00 | Continuously in outage from last month. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month. | 100.0000% |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 03-05-2024 10:30 | 03-05-2024 16:33 | 00:00 | 00:00 | 00:00 | 06:03 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL) | 03-05-2024 10:32 | 03-05-2024 16:36 | 00:00 | 00:00 | 00:00 | 06:04 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 04-05-2024 10:18 | 04-05-2024 15:58 | 00:00 | 00:00 | 00:00 | 05:40 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL) | 04-05-2024 10:23 | 04-05-2024 18:00 | 00:00 | 00:00 | 00:00 | 07:37 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 05-05-2024 10:41 | 05-05-2024 15:59 | 00:00 | 00:00 | 00:00 | 05:18 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL) | 05-05-2024 10:45 | 05-05-2024 16:05 | 00:00 | 00:00 | 00:00 | 05:20 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 06-05-2024 09:37 | 10-05-2024 22:46 | 00:00 | 00:00 | 00:00 | 109:09 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL) | 06-05-2024 09:23 | 10-05-2024 22:43 | 00:00 | 00:00 | 00:00 | 109:20 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 13-05-2024 09:14 | 01-06-2024 00:00 | 00:00 | 00:00 | 00:00 | 446:46 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month. | |
| 400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL) | 13-05-2024 09:17 | 01-06-2024 00:00 | 00:00 | 00:00 | 00:00 | 446:43 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month. | |

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2024

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|--|--------------------------------------|
| NIL | NIL | NIL |
| NIL | NIL | NIL |

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2024

Schedule III

| Element Name | Violation of Regulation | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|---------------------------|-----------------------|--|--------------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |