

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of August 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Jalandhar (PG)-Samba (PG)-I	16/08/2024 10:31	16/08/2024 18:08	0:00	0:00	0:00	7:37	Shutdown availed by CPCC2 for Line equipment AMP work. <b>Only line portion under the ownership of NRSS-XXIX.</b>	
400 kV Jalandhar (PG)-Samba (PG)-II	20/08/2024 12:12	20/08/2024 18:33	0:00	0:00	0:00	6:21	Shutdown availed by CPCC2 for Line equipment AMP work. <b>Only line portion under the ownership of NRSS-XXIX.</b>	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01/08/2024 00:00	01/09/2024 00:00	0:00	0:00	0:00	744:00	Continuously in outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation. <b>Still not charged in this month.</b>	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	01/08/2024 00:00	01/09/2024 00:00	0:00	0:00	0:00	744:00	Continuously in outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation. <b>Still not charged in this month.</b>	

**NRSS-XXIX Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of August 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL