

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of July 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Sambha-Amargarh Ckt-2	19/07/2024 15:55	19/07/2024 17:55	2:00	0:00	0:00	0:00	Emergency outage availed for attending hotspot.	
400kV Sambha-Amargarh Ckt-1	22/07/2024 16:15	22/07/2024 18:23	2:08	0:00	0:00	0:00	Emergency outage availed for attending hotspot.	
400kV UriI(NHPC)-Amargarh(NRSS)-1	06-07-2024 16:35	06-07-2024 18:54	0:00:00	0:00:00	0:00:00	2:19:00	Emergency S/D availed by PGCIL for tree cutting work between span 24-25	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01-07-2024 00:00	07-07-2024 01:12	0:00:00	0:00:00	0:00:00	145:12:00	Continuously in outage from February'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	01-07-2024 00:00	19-07-2024 02:36	0:00:00	0:00:00	0:00:00	434:36:00	Continuously in outage from February'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	17-07-2024 16:52	01-08-2024 00:00	0:00:00	0:00:00	0:00:00	343:08:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	20-07-2024 10:22	01-08-2024 00:00	0:00:00	0:00:00	0:00:00	277:38:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	

NRSS-XXIX Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL