

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of June 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Sambha-Amargarh Ckt-2	13/06/2024 12:22	13/06/2024 14:01	1:39	0:00	0:00	0:00	Emergency outage availed for tree trimming	99.9488%
400 kV Jalandhar (PG)-Samba (PG)-II	21/06/2024 13:36	21/06/2024 14:47	0:00	0:00	0:00	1:11	Emergency shutdown availed by PGCIL for rectification of R-phase Jumper Broken Connector of R-phase BPI at Sambha Substation. Only Line portion under the ownership of NRSS.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01-06-2024 00:00	01-07-2024 00:00	0:00:00	0:00:00	0:00:00	720:00:00	Continuously in outage from February'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	01-06-2024 00:00	01-07-2024 00:00	0:00:00	0:00:00	0:00:00	720:00:00	Continuously in outage from February'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	

NRSS-XXIX Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of June 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL