

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Jalandhar (PG)-Samba (PG)-II	24/05/2024 18:35	24/05/2024 22:32	3:57	0:00	0:00	0:00	Line tripped due to Y-phase to Earth fault.	99.9444%
400 kV Jalandhar (PG)-Samba (PG)-I							NO Tripping / Outage for the month of MAY24	
400kV Sambha-Amargarh Ckt-1							NO Tripping / Outage for the month of MAY24	
400kV Sambha-Amargarh Ckt-2							NO Tripping / Outage for the month of MAY24	
400kV Uri1(NHPC)-Amargarh(NRSS)-1							NO Tripping / Outage for the month of MAY24	
400kV Uri1(NHPC)-Amargarh(NRSS)-2							NO Tripping / Outage for the month of MAY24	
400kV Amargarh(NRSS)-Wagoora(PG)-2							NO Tripping / Outage for the month of MAY24	
400/220 kV, 315 MVA-1 at Amargarh							NO Tripping / Outage for the month of MAY24	
400/220 kV, 315 MVA-2 at Amargarh							NO Tripping / Outage for the month of MAY24	
400kV Amargarh(NRSS)-Wagoora(PG)-1	30/05/2024 09:40	30/05/2024 18:24	0:00	0:00	0:00	8:44	Shutdown availed by PGCIL for retrofitting of equipments under ADD CAP works at wagoora SS.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01/05/2024 00:00	01/06/2024 00:00	0:00	0:00	0:00	744:00	Continuously in outage from February'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	01/05/2024 00:00	01/06/2024 00:00	0:00	0:00	0:00	744:00	Continuously in outage from February'24. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	

NRSS-XXIX Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL