

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of August 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400KV Patiala-Patran-2	16/08/2024 09:22	17/08/2024 01:28	0:00	0:00	0:00	16:06	PTCL Taken the shutdown for safety purpose during erection of side wall puff panels at 400 kV PEB building under the recently awarded Augmentation scheme by CTUIL for additional 500MVA Transformer Installation at PTCL SS. Enclosed here with the CTUIL OM issued to PTCL for the Augmentation Scheme.	

Patran Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL