

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of June 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee  Hrs:Min	Others  Hrs:Min	System constraint/ Natural calamity/ Militancy  Hrs:Min	Deemed Available  Hrs:Min		
400KV Patiala-Patran-1	01/06/2024 11:24	01/06/2024 12:15	0:00	0:00	0:00	0:51	Emergency shutdown availed by PGCIL for removing kites' threads and foreign material at location No. 244. This portion of line is outside the ownership of PTCL. Only 100Mtrs line under the ownership of PTCL.	100.00%
400KV Patiala-Patran-2	12/06/2024 16:18	12/06/2024 17:55	0:00	0:00	0:00	1:37	Emergency shutdown availed by PGCIL for removing kites threads hanging at Location No.-328 This portion of line is outside the ownership of PTCL. Only 100Mtrs line under the ownership of PTCL.	

**Patran Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of June 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL