

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of May 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400KV Patiala-Patran-1	14/05/2024 16:36	14/05/2024 21:26	0:00	0:00	0:00	4:50	Emergency shutdown availed for replacement of damaged insulator. This portion of line is outside the ownership of PTCL.	100.00%
400KV Patiala-Patran-1	15/05/2024 07:07	15/05/2024 13:02	0:00	0:00	0:00	5:55	Emergency shutdown availed for replacement of damaged insulator. This portion of line is outside the ownership of PTCL.	
400KV Kaithal -Patran-1							NO Tripping / Outage for the month of MAY24	
400KV Kaithal -Patran-2							NO Tripping / Outage for the month of MAY24	
400KV Patiala-Patran-2							NO Tripping / Outage for the month of MAY24	
400/220 KV ICT-1 at Patran							NO Tripping / Outage for the month of MAY24	
400/220 KV ICT-2 at Patran							NO Tripping / Outage for the month of MAY24	

Patran Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL