

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of April 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time		Date Time		Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs.Min	Hrs.Min	Hrs.Min	Hrs.Min		
400kV Parbati 3-400kV Banala Pooling Station	01/04/2024	11:58	01/04/2024	19:32	0:00	0:00	0:00	7:34	S/D availed by CPCC-2 for damaged insulator replacement work.	100.00%
400kV Parbati 3 - Sainj HEP	02/04/2024	10:53	02/04/2024	18:41	0:00	0:00	0:00	7:48	Emergency shutdown availed for replacement of broken Insulator at T. No-7 which is not under ownership of the licensee.	
400kV Parbati 3 - Sainj HEP	08/04/2024	16:23	08/04/2024	18:50	0:00	0:00	0:00	2:27	Emergency shutdown availed by PARBATI-III-NH for CB Testing of newly installed CB Pole in Bus Coupler. Line was idle charged from Sainj(HP) end.	
400kV Parbati 3-400kV Banala Pooling Station	08/04/2024	16:22	08/04/2024	18:20	0:00	0:00	0:00	1:58	Emergency shutdown availed by PARBATI-III-NH for CB Testing of newly installed CB Pole in Bus Coupler. Line was idle charged from Parbati Pooling Banala(PG) end.	
400kV Koldam-Ludhiana Ckt 1	01/04/2024	02:00	01/04/2024	06:18	0:00	0:00	0:00	4:18	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 2	01/04/2024	22:03	02/04/2024	05:52	0:00	0:00	0:00	7:49	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	02/04/2024	22:56	03/04/2024	05:28	0:00	0:00	0:00	6:32	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	
400kV Koldam-Ludhiana Ckt 1	08/04/2024	00:40	08/04/2024	06:23	0:00	0:00	0:00	5:43	Line was hand tripped as per RLDC instruction due to Voltage Regulation.	

Parbati Koldam Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL