

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of June 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to			Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available			
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min			
400 KV Nallagarh(PG)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	01/06/2024 09:42	10/06/2024 00:00	0:00	0:00	206:18	0:00	Line shutdown availed for diversion/tower replacement work at TN 56, impacted due to heavy rainfall and adverse weather conditions in the month of July 2023 & August 2023 which damaged the transmission line by unforeseeable Force Majeure circumstances beyond control of licensee. Additionally, the HP State Government, vide its notification dated 18.08.2023, declared the entire state of HP as a "Natural Calamity Affected Area". (Copy enclosed) Also Enclosed here with the NRPC committee report recommendation regarding the diversion/tower replacement work. Please consider the outage period under Force Majeure condition.		
400kV Koldam-Ludhiana Ckt 2	22/06/2024 16:04	22/06/2024 18:27	0:00	0:00	0:00	2:23	Shutdown availed by CPCC2 to attend hotspot in Line isolator terminal of around 145 degree Celsius at Ludhiana SS. Only line portion under the ownership of PKTCL.		

Parbati Koldam Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of June 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL