

**Maheshwaram Transmission Limited**

**I. AC Transmission Line Outage Details for the month of AUGUST 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	01-08-2024	00:00:00	05-08-2024	07:05:00	0:00	0:00	0:00	103:05	As per SRLDC instruction the line was taken out due to power regulation(over loading). Load before out of service : 516 MW Outage Code -3377 Charging Code - 610	99.89%
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	21-08-2024	10:55:00	21-08-2024	14:55:00	4:00	0:00	0:00	0:00	Outage availed for AMP Work for Line and Bays at Mehboobnagar. Shutdown availed by TSTRANSCO. <b>Line and Bays at TSTRANSCO end are under the ownership of MTL.</b> Outage Code: 2450 Charging Code :  TSTRANSCO requested PGCIL to cancel the PTW at 14:55HRS, enclosed here with the TSTRANSCO permit copy and mobile message sent to PGCIL for the cancellation of NBFC.	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	21-08-2024	14:55:00	22-08-2024	20:18:00	0:00	0:00	0:00	29:23	TSTRANSCO requested PGCIL to cancel the PTW at 14:55HRS, enclosed here with the TSTRANSCO permit copy and mobile message sent to PGCIL for the cancellation of NBFC for reference. NBFC was not cancelled from PGCIL end due to an abnormal Tan Delta result observed in the CVT-Y Phase at the Maheshwaram end. 1. At 14:55 hours on 21-08-2024, TSTRANSCO completed the work and requested PGCIL for cancellation of NBFC and PTW. 2. At 21:22 hours on 21-08-2024, an information email was sent by RTAMC SR1 to IndiGrid, indicating that the CVT-Y-phase tan delta results at the Maheshwaram end were found to be abnormal. 3. At 20:18 hours on 22-08-2024, the line was finally charged. <b>Line and Bays are under the ownership of MTL.</b>  Kindly consider this outage period under others account because only line portion and TSTRANSCO end bay under the ownership of MTL. Outage Code: Charging Code : 2606	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	29-08-2024	15:06:00	29-08-2024	18:12:00	0:00	0:00	0:00	3:06	As per SRLDC instruction the line was taken out due to power regulation(over loading). Load before out of service : 387 MW Outage Code: 3474 Charging Code : 3521	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2					0	0	0	0	No Tripping / outage for the month of August-24.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0	0	0	0	No Tripping / outage for the month of August-24.	

**Maheshwaram Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of AUGUST 2024**

**Schedule II**

I. AC Transmission Line Outage Details for the month of AUGUST 2024

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of AUGUST 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil