

**Maheshwaram Transmission Limited**

**I. AC Transmission Line Outage Details for the month of JULY 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2	21-07-2024	12:36:00	26-07-2024	18:22:00	0:00	0:00	0:00	125:46	As per SRLDC instruction the line was taken out due to power regulation(over loading) Outage Code -2577 Charging Code -3287	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	27-07-2024	14:12:00	01-08-2024	00:00:00	0:00	0:00	0:00	105:48	As per SRLDC instruction the line was taken out due to power regulation(over loading), Still not yet charged in this month. Outage Code -3377 Charging Code -	
400kV Nizamabad(PG)-Shankarapally(TS) Line-2					0:00	0:00	0:00	0:00	No Tripping / outage for the month of July-24.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0:00	0:00	0:00	0:00	No Tripping / outage for the month of July-24.	

**Maheshwaram Transmission Limited****II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JULY 2024****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of JULY 2024****Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil