

Raichur Sholapur Transmission Company Private Limited

I. AC Transmission Line Outage Details for the month of MAY 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
RAICHUR - SHOLAPUR II	18-05-2024	11:38:00	18-05-2024	12:28:00	0:00:00	0:50:00	0:00:00	0:00:00	RSTCPL taken emergency shutdown to facilitate insulator replacement work at Tower No. 228. The line was shut down at 11:38 AM. However, due to Unknown reason , PTW (Permit to Work) for the same was issued at 12:28PM. Kindly please consider additional ouatge hours into other account. We have enclosed the email communication for your reference. Shutdown Code - 2145	99.35%
RAICHUR - SHOLAPUR II	18-05-2024	12:28:00	18-05-2024	17:19:00	4:51:00	0:00:00	0:00:00	0:00:00	RSTCPL taken the emergency shutdown for insulator replacement work at Tower No. 228. PTW for the same was issued at 12:28Hrs. Charging clearance was given at 17:19Hrs and charging code was received at 17:29Hrs and line was finally charged at 18:49Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason enclosed here with the email copy. While only the line portion falls under the jurisdiction of RSTCPL, the terminal equipment of the bay is owned by PGCIL.	
RAICHUR - SHOLAPUR II	18-05-2024	17:19:00	18-05-2024	18:49:00	0:00:00	1:30:00	0:00:00	0:00:00	Charging clearance was given at 17:19Hrs and charging code was received at 17:29Hrs and line was finally charged at 18:49Hrs. The delay in charging, following the receipt of the charging code was due to unknown reason enclosed here with the email copy. While only the line portion falls under the jurisdiction of RSTCPL, the terminal equipment of the bay is owned by PGCIL. Request to please consider addition outage hours into other account. Charging Code - 2177	

**Raichur Sholapur Transmission Company Private Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

