

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of AUG 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV Dhule(BDTCL) - Vadodara(PG)	11-08-2024	11:25:00	11-08-2024	19:16:00	07:51	00:00	00:00	00:00	Due to Y-phase to Earth fault. Tripping Converted into emergency S/D. WRLDC - 1223 Y-Phase insulator found damaged. Dhule End : M1-168km, 3.711kA ; M2-165.08km, 3.8kA Vadodara End : M1-74km, 6.1kA ; M2-74.9km, 6.3kA	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2	12-08-2024	05:09:00	12-08-2024	09:40:00	00:00	04:31	00:00:00	00:00	Due to Y-phase to Earth fault. Dhule End : M1-17.5km, 5.2kA (Zone-2) ; M2-NA, NA MSETCL End:M1-NA, NA (Zone-1); M2-NA, NA. Communication from MSETCL Side: At 400kV Dhule R/S, 400/220kV 501MVA ICT-3 tripped due to Yph Bushing burst at 05:09Hrs. dt.12.08.2024 Due to this 400KV Main Bus -2 connected feeder trip	
765kV Dhule(BDTCL) - Vadodara(PG)	12-08-2024	14:53:00	12-08-2024	22:36:00	07:43	00:00	00:00	00:00	Due to B-phase to Earth fault. Tripping Converted into emergency S/D. WRLDC -1337 B-Phase insulator found damaged. Dhule End : M1-170.3km, 3.5kA ; M2-169km, 3.6kA Vadodara End:M1-73.58km,6.28kA; M2-73.98km 6.27kA	
765kV Dhule(BDTCL) - Vadodara(PG)	23-08-2024	11:41:00	23-08-2024	11:41:00	00:00	00:00	00:00	00:00	Due to R-phase to Earth fault. Dhule End : M1-175.7km, 3.2kA ; M2-171.3km, 3.5kA Vadodara End:M1-83.74km,6.38kA; M2-84.38km 6.38kA	
BHOPAL-INDORE 765 KV LINE	24-08-2024	12:09:00	24-08-2024	14:20:00	02:11	00:00	00:00	00:00	Emergency Shutdown to rectify open jumper wire at Tower No. 164	
400 KV Bus Reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 KV Bus Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 KV Indore LR at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 kv bus reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 KV Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765KV S/C Aurangabad-Dhule Line					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of AUG24	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil