

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of JUL 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400 KV Bus Reactor at BDTCL Bhopal	01-07-2024	12:34:00	01-07-2024	18:05:00	05:31	00:00	00:00	00:00	Emergency Shutdown was taken to attend oil leak which was observed during routine checks.	
765 KV Bus Reactor at BDTCL Dhule	08-07-2024	06:37:00	11-07-2024	02:22:00	00:00	00:00	67:45:00	00:00	Due to Voltage Regulation	
765kV Dhule(BDTCL) - Vadodara(PG)	17-07-2024	05:55:00	17-07-2024	05:55:00	00:00	00:00	00:00	00:00	Due to Y-Phase to Earth Fault	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line	22-07-2024	15:29:00	22-07-2024	16:55:00	01:26	00:00	00:00	00:00	Due to Y-Phase to Earth Fault	
BHOPAL-INDORE 765 KV LINE	28-07-2024	12:27:00	28-07-2024	12:27:00	00:00	00:00	00:00	00:00	A/R operated successfully Due to Y-Phase to Earth Fault. LR tripped during AR operated.	
765 KV Indore LR at BDTCL Bhopal	28-07-2024	12:27:00	28-07-2024	13:27:00	00:00	00:00	01:00	00:00	LR tripped during auto recloser operate at 12:27 hrs on 28-07-2024 due to under the tripping scheme implemented against ferro-resonance effect.	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No outages in this month	
765 kv bus reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 kv Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765KV S/C Aurangabad-Dhule Line					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil