

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of MAY 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765 KV Bus Reactor at BDTCL Dhule	06-05-2024	09:25:00	08-05-2024	04:13:00	0:00	0:00	0:00	42:48	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	13-05-2024	14:40:00	13-05-2024	21:19:00	0:00	0:00	0:00	6:39	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Indore LR at BDTCL Bhopal	13-05-2024	04:04:00	13-05-2024	05:01:00	0:00	0:57	0:00	0:00	As per 129PCM recommendation, At BDTCL Bhopal S/S during the single Phase fault and A/R in order for 765kV Bhopal Indore Line the Switchable Line Reactor (SLR) have to be trip to avoid ferroresonance, Scheme has been implement as per the decision of 129 PCM.	
BHOPAL-INDORE 765 KV LINE	13-05-2024	04:04:00	13-05-2024	04:04:00	0:00	0:00	0:00	0:00	A/R successful due to transient Y Phase to Earth fault. FL is 7.4Kms from Bhopal SS & FC is 9.51KA.	
765 KV Bus Reactor at BDTCL Dhule	21-05-2024	12:16:00	23-05-2024	21:58:00	0:00	0:00	0:00	57:42	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Dhule(BDTCL) - Vadodara(PG)	29-05-2024	17:17:00	29-05-2024	19:05:00	0:00	1:48	0:00	0:00	Shutdown availed by POWERGRID_WR2 for Oil leakage rectification of Y-phase Line reactor at Vadodara end	
400 KV Bus Reactor at BDTCL Bhopal	29-05-2024	02:14:00	29-05-2024	09:09:00	6:55	0:00	0:00	0:00	Tripped due to PRV-02 operated.	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					0:00	0:00	0:00	0:00	No outages in this month	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No outages in this month	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765 kV Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line					0:00	0:00	0:00	0:00	No outages in this month	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No outages in this month	
765 kv bus reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No outages in this month	
765KV S/C Aurangabad-Dhule Line					0:00	0:00	0:00	0:00	No outages in this month	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil