

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of APR 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	08-04-2024	22:35:00	08-04-2024	23:37:00	0:00	0:00	1:02	0:00	Tripped due to transient B-phase to Earth fault due to foreign material came in contact with the line due to inclemnet weather condition, enclosed here with the patrolling report along with Photograph and newspaper currtng for reference. Charging clearance was given at 23:15Hrs and Test charge attempt taken from Dharamjaygarh end at 23:37Hrs, However the test attempt failed due to over voltage protection operated at Jabalpur SS. Tripping converted into voltage regulation as per RLDC instruction	
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	08-04-2024	23:37:00	09-04-2024	06:23:00	0:00	0:00	0:00	6:46	Tripping converted into voltage regulation as per RLDC instruction, enclosed here with the email copy.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	08-04-2024	19:21:00	08-04-2024	19:21:00	0:00	0:00	0:00	0:00	A/R successful due to transient B Phase to Earth fault.	
765kV Jabalpur-Bina III	12-04-2024	17:38:00	12-04-2024	17:38:00	0:00	0:00	0:00	0:00	A/R successful due to transient B Phase to Earth fault.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	16-04-2024	17:41:00	16-04-2024	17:41:00	0:00	0:00	0:00	0:00	A/R successful due to transient B Phase to Earth fault.	

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil