

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of JUL 2024

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % |
|---|------------|----------|-------------|----------|---|----------------|--|--------------------------|--|---|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 765kV JTCL Dharamjaygarh-Jabalpur CKT-4 | 09-07-2024 | 15:07:00 | 09-07-2024 | 16:50:00 | 01:43 | 00:00 | 00:00 | 00:00 | Due to R-phase to Earth fault. Note: At the time of tripping AR function was not enabled from Jabalpur end we have already sent email along with grid code for AR-ON. E-mail copy attached for reference | |
| 765kV JTCL Dharamjaygarh-Jabalpur CKT-4 | 14-07-2024 | 18:32:00 | 14-07-2024 | 20:10:00 | 01:38 | 00:00 | 00:00 | 00:00 | Due to B-phase to Earth Fault | |
| 765kV JTCL Dharamjaygarh-Jabalpur CKT-4 | 16-07-2024 | 01:01:00 | 16-07-2024 | 03:15:00 | 02:14 | 00:00 | 00:00 | 00:00 | Due to R-phase to Earth Fault | |
| 765kV JTCL Dharamjaygarh-Jabalpur CKT-3 | 17-07-2024 | 23:11:00 | 18-07-2024 | 21:51:00 | 22:40 | 00:00 | 00:00 | 00:00 | Due to R-Phase to B-Phase fault. Test charge attempt for the 765kV D/C Jabalpur-Dharamjaygarh Ckt-03, as per grid code WRLDC-1953 / NLDC-1245, failed at 01:49 hours today (i.e., 18-07-2024) due to an R-Phase to B-Phase fault from the Dharamjaygarh end. Dharamjaygarh end. Emergency shutdown code received WRLDC-2012 at 14:56 hrs. | |
| 765kV JTCL Dharamjaygarh-Jabalpur CKT-3 | 23-07-2024 | 16:19:00 | 30-07-2024 | 20:52:00 | 00:00 | 00:00 | 00:00 | 172:33 | Line hand tripped as per RLDC instruction due to voltage regu | |
| 765kV Jabalpur-Bina III | 22-06-2024 | 16:37:00 | 22-06-2024 | 16:37:00 | 00:00 | 00:00 | 00:00 | 00:00 | No trippings this month for this element | |

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2024

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |
| Nil | Nil | Nil |

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2024

Schedule III

| Element Name | Violation of Regulation 5(a) | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|------------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |