

Jabalpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of MAY 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	08-05-2024	17:06:00	08-05-2024	17:06:00	00:00	00:00	00:00	00:00	A/R successful due to transient B Phase to Earth fault. FL is 115Kms from Jabalpur & FC is 6.097KA.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	09-05-2024	02:17:00	09-05-2024	02:17:00	00:00	00:00	00:00	00:00	A/R successful due to transient B Phase to Earth fault. FL is 50.36Kms from Jabalpur & FC is 10.79KA.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	10-05-2024	17:44:00	10-05-2024	21:02:00	03:18	00:00	00:00	00:00	Line tripped on Ph to Ph transient fault due to inclement weather condition and also due to foreign material came in contact with the line which causes tripping, this is for the information that the said line is double circuit line and Ph to Ph fault was generally happened due to transient nature of fault. 1. Charging clearance was given at 20:32 hrs. 2. Charging code was received at 21:15 hrs. 3. charging attempt was taken at 21:57 hrs. during which the line again tripped due to overvoltage operated at Jabalpur SS. JTCL considered addition 30minutes into JTCL account from the charging clearance time. Request to consider the remaining period under 'Others' category as the delay was beyond the control of the Licensee and only the line portion belongs to JTCL. Enclosed here with the email communication, EGP and newspaper cutting for your reference.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	10-05-2024	21:02:00	10-05-2024	22:23:00	00:00	01:21	00:00	00:00	1. Charging clearance was given at 20:32 hrs. 2. Charging code was received at 21:15 hrs. 3. charging attempt was taken at 21:57 hrs. during which the line again tripped due to overvoltage operated at Jabalpur SS. JTCL considered addition 30minutes into JTCL account from the charging clearance time. Line was charged with the same charging code at 22:33Hrs. Request to consider the remaining period under 'Others' category as the delay was beyond the control of the Licensee and only the line portion belongs to JTCL.	
765kV Jabalpur-Bina III	27-05-2024	13:49:00	27-05-2024	17:27:00	03:38	00:00	00:00	00:00	Line tripped due to Y-phase to Earth fault. 1. Charging clearance was given at 16:57 hrs. 2. Charging code was received at 17:11 hrs. 3. Line was finally charged at 18:09 hrs, charging was delayed due to closing issue at Bina SS. JTCL considered addition 30minutes into JTCL account from the charging clearance time.	
765kV Jabalpur-Bina III	27-05-2024	17:27:00	27-05-2024	18:09:00	00:00	00:42	00:00	00:00	Line was finally charged at 18:09 hrs, charging was delayed due to closing issue at Bina SS. JTCL considered addition 30minutes into JTCL account from the charging clearance time. Enclosed here with the email communication for reference.	

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of May 2024**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil