

**Khargone Transmission Limited**

**I. AC Transmission Line Outage Details for the month of APR 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400 KV PARLI (PG) - KALLAM PS (KTL) CKT - 2 (LILO P	11-04-2024	16:36:00	11-04-2024	20:20:00	0:00	0:00	0:00	44:20	Continuously in outage from previous month. Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125MVAR BR-1 AT KTL KALLAM PS	15-04-2024	09:54:00	15-04-2024	17:55:00	0:00	0:00	0:00	367:55	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400 KV KALLAM PS (KTL) - PUNE (GIS) CKT - 1 (LILO P	17-04-2024	16:10:00	17-04-2024	15:13:00	5:01	0:00	0:00	0:00	Emergency shutdown availed for jumper corona free suspension clamp replacement work at tower no - 60.	
400 KV KALLAM PS (KTL) - PUNE (GIS) CKT - 2 (LILO P	24-04-2024	20:38:00	25-04-2024	18:30:00	0:00	0:00	0:00	129:42	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125MVAR BR-1 AT KTL KALLAM PS	24-04-2024	09:20:00	24-04-2024	10:56:00	0:00	1:44	0:00	0:00	Shutdown availed for defect rectification work. NBFC code received at 10:56Hrs from RTAMC-WR2 due to isolator issue. Request to consider this period under 'Others' category as this was beyond the control of the licensee.	
400kV 125MVAR BR-1 AT KTL KALLAM PS	29-04-2024	09:43:00	01-05-2024	19:23:00	8:27	0:00	0:00	0:00	E-mail communication attached herewith for your reference. PTW issued at 10:56Hrs for defect rectification work.	
400 KV PARLI (PG) - KALLAM PS (KTL) CKT - 1 (LILO P	28-03-2024	08:50:00	28-03-2024	16:42:00	7:52	0:00	0:00	0:00	Shutdown availed for defect rectification work. Charging clearance given at 16:23 hrs, charging code was issued at 16:42Hrs and line was finally charged at 18:14Hrs. Delayed in charging was due to unknown reasons.	
400/220kV 500MVA ICT 1 AT KTL KALLAM PS	28-03-2024	16:42:00	28-03-2024	18:14:00	0:00	1:32	0:00	0:00	Enclosed here with the email communication for your reference. Charging clearance given at 16:23 hrs, charging code was issued at 16:42Hrs and line was finally charged at 18:14Hrs. Delayed in charging was due to unknown reasons.	
400/220kV 500MVA ICT 2 AT KTL KALLAM PS	28-03-2024	09:20:00	28-03-2024	23:19:00	0:00	0:00	0:00	13:59	Shutdown availed by POWERGRID_WR2 For LBB and Bus bar relay testing work. Only line portion under the ownership of KTL.	
400kV KALLAM PS (KTL) - PUNE (GIS) 50MVAR LR-1 AT KTL KALLAM PS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV KALLAM PS (KTL) - PUNE (GIS) 50MVAR LR-2 AT KTL KALLAM PS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited****II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2024****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of April 2024****Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil