

Khargone Transmission Limited

I. AC Transmission Line Outage Details for the month of APR 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765KV-Dhule-Khandwa-Sterlite-1	09-04-2024	15:34:00	09-04-2024	17:01:00	0:00	0:00	1:27	0:00	Line tripped on transient R-Phase to Earth Fault due to inclement weather condition and also may be due to foreign material came in contact with the line which causes tripping. Attached here with the RCA Report for your reference and also enclosed the News paper cutting. This incident is beyond the control of licensee.	
765KV-Indore-Khandwa-Sterlite-2	09-04-2024	16:21:00	09-04-2024	17:42:00	0:00	0:00	1:21	0:00	Line tripped on transient R-Phase to Earth Fault due to inclement weather condition and also may be due to foreign material came in contact with the line which causes tripping. Attached here with the RCA Report for your reference and also enclosed the News paper cutting. This incident is beyond the control of licensee.	
765kV Khandwa-Dhule-LR-1 at Khandwa SS	09-04-2024	15:34:00	09-04-2024	17:01:00	0:00	0:00	0:00	1:27	As per CTU charging instruction, At Khandwa S/S during the single Phase fault and A/R in order for 765kV Khandwa - Dhule Line, the Switchable Line Reactor (SLR) have to be trip to avoid ferroresonance, Scheme has been implement as per the decision.	
765KV-Indore-Khandwa-Sterlite-2	16-04-2024	12:23:00	16-04-2024	19:51:00	0:00	0:00	0:00	7:28	Shutdown availed by PGCIL-WR2 for AMP work of LR at Indore end	
400kV Khandwa-Khargone(NTPC) Line	23-04-2024	09:40:00	24-04-2024	04:14:00	0:00	0:00	0:00	18:34	Shutdown availed by POWERGRID_WR2 for LBB retrofitting work. Only L1LO portion under the ownership of KTL.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	25-04-2024	15:11:00	25-04-2024	20:25:00	0:00	0:00	0:00	5:14	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765kV Khandwa-KTL-BR-1 at Khandwa SS	27-04-2024	09:40:00	27-04-2024	21:51:00	0:00	0:00	0:00	12:11	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765KV-Indore-Khandwa-Sterlite-1	30-04-2024	10:19:00	30-04-2024	19:04:00	0:00	0:00	0:00	8:45	Shutdown availed by PGCIL-WR2 for AMP work of Line terminal equipment & Line Reactor Work at PGCIL SS.	
400kV Khandwa Pool-Khargone TPP Ckt-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khargone(NTPC)-Rajgarh Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited****II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of APR 2024****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of APR 2024****Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil