

**Khargone Transmission Limited**

**I. AC Transmission Line Outage Details for the month of AUG 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765KV-Dhule-Khandwa-Sterlite-1	05-08-2024	01:01:00	05-08-2024	10:07:00	0:00	0:00	9:06	0:00	Due to Voltage Regulation	
765kV Khandwa-KTL-BR-1 at Khandwa SS	11-08-2024	09:21:00	11-08-2024	14:30:00	5:09	0:00	0:00	0:00	Due to SF6 Lockout maloperation in 408 Tie Bay SF6 CT.	
400kV Khargone(NTPC)-Rajgarh Line	23-08-2024	10:25:00	23-08-2024	20:25:00	0:00	10:00	0:00	0:00	As per third party protection audit by CPRI to be implemented in phased manner & CB Testing. S/D availed by NTPC.	
400kV Khandwa-Khargone(NTPC) Line	24-08-2024	10:17:00	24-08-2024	19:23:00	0:00	9:06	0:00	0:00	As per third party protection audit by CPRI to be implemented in phased manner & CB Testing. S/D availed by NTPC.	
400kV Khandwa Pool-Khargone TPP Ckt-2	26-08-2024	10:13:00	26-08-2024	19:36:00	0:00	9:23	0:00	0:00	As per third party protection audit by CPRI to be implemented in phased manner & CB Testing. S/D availed by NTPC.	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS	30-08-2024	04:50:00	30-08-2024	09:56:00	5:06	0:00	0:00	0:00	Due to malfunction of 706-CT SF6 lockout	
765KV-Indore-Khandwa-Sterlite-2	30-08-2024	20:20:00	30-08-2024	23:20:00	3:00	0:00	0:00	0:00	For attending hotspot on R-phase wave trap nut-bolt (At 22:50 Hrs Khandwa end line isolator closed and At 23:15 Hrs Line isolator closing confirmation received from RTAMC-WR2)	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of AUG 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of AUG 2024**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil