

**Khargone Transmission Limited**

**I. AC Transmission Line Outage Details for the month of JUN 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Khargone(NTPC)-Rajgarh Line	17-06-2024	08:39:00	17-06-2024	21:58:00	0:00	13:19	0:00	0:00	for AR Relay retrofitting work	
400kV Khargone(NTPC)-Rajgarh Line	18-06-2024	08:34:00	18-06-2024	23:15:00	0:00	14:41	0:00	0:00	For AR Relay retrofitting work, Note: Shutdown availed by POWERGRID WR2. Opportunity code Received by-WRLDC-2083.	
400kV Khandwa-Khargone(NTPC) Line	19-06-2024	09:47:00	19-06-2024	23:20:00	0:00	13:33	0:00	0:00	For Insulator replacement works of Road crossing and vulnerable location (Opportunity code: WR-2210) and cancellation code WR-2231).	
400kV Khandwa Pool-Khargone TPP Ckt-2	24-06-2024	02:12:00	24-06-2024	02:12:00	0:00	0:00	0:00	0:00	Due to R phase to Earth fault	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV-Indore-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV-Dhule-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV-Dhule-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of June 2024**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil