

**Khargone Transmission Limited**

**I. AC Transmission Line Outage Details for the month of MAY 2024**

**Schedule I**

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765KV-Dhule-Khandwa-Sterlite-2	26-05-2024	16:26:00	26-05-2024	19:17:00	2:51	0:00	0:00	0:00	Line tripped on transient R-Ph to r-Ph transient fault due to inclement weather condition and may be due to foreign material came in contact with the line which causes tripping, this is for the information that the said line is double circuit line and Ph to Ph fault was generally happened due to transient nature of fault. Enclosed here with the newspaper cutting and photo of impacted location near to line. This incident is beyond the control of licensee. Charging clearance was given at 18:29Hrs and charging code for the same was received at 19:05 and line was finally charged at 19:16Hrs.	
765kV Khandwa-Dhule-LR-2 at Khandwa SS	26-05-2024	16:26:00	26-05-2024	19:17:00	0:00	2:51	0:00	0:00	As per CTU charging instruction, At Khandwa S/S during the single Phase fault and A/R in order for 765kV Khandwa - Dhule Line, the Switchable Line Reactor (SLR) have to be trip to avoid ferroresonance, Scheme has been implement as per the decision.	
765KV-Dhule-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-Khargone(NTPC) Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765KV-Indore-Khandwa-Sterlite-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-2					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-2 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765/400kV Khandwa-KTL-ICT-2 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa-KTL-BR-1 at Khandwa SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khandwa Pool-Khargone TPP Ckt-1					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
765kV Khandwa-Dhule-LR-1 at Dhule SS					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	
400kV Khargone(NTPC)-Rajgarh Line					0:00	0:00	0:00	0:00	NO Tripping / Outages in this month	

**Khargone Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2024**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil