

RAPP Transmission Company Limited

I. AC Transmission Line Outage Details for the month of April 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV RAPP-Sujalpur Ckt-2	12-04-2024	16:42:00	04-12-2024	16:42:00	0:00	0:00	0:00	0:00	AR success due to transient R-phase to earth fault.	
400kV RAPP-Sujalpur Ckt-2	26-04-2024	08:05:00	26-04-2024	08:05:00	0:00	0:00	0:00	0:00	AR success due to transient R-phase to earth fault.	
400kV RAPP-Sujalpur Ckt-1					0:00	0:00	0:00	0:00	No outages in this month	

RAPP Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil

