

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of OCTOBER 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	01-10-2024 00:00	01-11-2024 00:00	0:00:00	0:00:00	0:00:00	744:00:00	Continuously in outage from Previous Month. As per the RLDC instruction Line was taken out of service due to voltage regulation. Still not charged in this month.	100.000%
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages For the month of October 24	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages For the month of October 24	
400kV D/C OPGC-LILO POINT (T. No. - 130)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages For the month of October 24	
400kV D/C LILO POINT (T. No. - 130) - Sundargarh			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages For the month of October 24	

Odisha Generation Phase-II Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCTOBER 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

Sl. No. Voltage Level Name of Line COD Line Length (No. of sub cor Weightage Factor (N:

III. Details of compensation paid by the inter-State transmission licensee for the month of OCTOBER 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil