

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of OCTOBER 2024

Schedule I

Element Name	Outage		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date & Time	Restoration Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400 kV Chaibasa-Kharagpur D/C line CKT- 1	01-10-2024 06:35	01-10-2024 11:29	0:00:00	0:00:00	0:00:00	4:54:00	WBSETCL taken the Emergency Shutdown for attending hotspot. Only Line Portion belongs to PKTCL.	99.940%
400 kV Chaibasa-Kharagpur D/C line CKT- 1	08-10-2024 11:25	08-10-2024 12:56	1:31:00	0:00:00	0:00:00	0:00:00	Line tripped due to Y-Ph to Earth fault. Charging clearance was given at 12:55 hrs, Charging code received at 12:56 hrs and Line was finally charged at 16:04 Hrs delayed in charging due to unknown reason at PGCIL Chaibasa SS.	
400 kV Chaibasa-Kharagpur D/C line CKT- 1	08-10-2024 12:56	08-10-2024 16:04	0:00:00	3:08:00	0:00:00	0:00:00	Charging clearance was given at 12:55 hrs, Charging code received at 12:56 hrs. However there was a delay in charging of line from RTAMC Patna due to unknown reason at PGCIL Chaibasa SS, Therefore the previously issued code was cancelled by ERLDC at 14:07hrs. ERLDC reissued charging code at 15:47hrs, and the line was finally charged at 16:04 hrs. Email communication attached herewith for your reference. Kindly consider this Outage period under Others Account.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2	22-10-2024 08:18	22-10-2024 16:42	0:00:00	0:00:00	0:00:00	8:24:00	WBSETCL taken the Emergency Shutdown for rectification of oil leakage in Y-phase CVT. Only Line Portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages For the month of October 24	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages For the month of October 24	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCTOBER 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of OCTOBER 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil