

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of SEPTEMBER 2024

Schedule I

| Element Name | Outage | | Duration of Outage Attributable to | | | | Reason of | % |
|---|------------------|----------------------------|--|-------------------|---|-----------------------------|--|--------------|
| | Date & Time | Restoration Date & Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | Outage | Availability |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-1 | 25-09-2024 11:18 | 25-09-2024 13:06 | 0:00:00 | 0:00:00 | 0:00:00 | 1:48:00 | PGCIL taken the shutdown for AMP of PPSP-II LR (Non-Switchable) & LR Bay. Only Line portion under the ownership of PKTCL. | 100.000% |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-1 | 25-09-2024 17:12 | 25-09-2024 18:24 | 0:00:00 | 0:00:00 | 0:00:00 | 1:12:00 | PGCIL taken the shutdown for taking back the Non-Switchable LR into service. Only Line portion under the ownership of PKTCL. | |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-2 | 26-09-2024 12:11 | 26-09-2024 14:20 | 0:00:00 | 0:00:00 | 0:00:00 | 2:09:00 | PGCIL taken the shutdown for AMP of PPSP-II LR (Non-Switchable) & LR Bay. Only Line portion under the ownership of PKTCL. | |
| 400 KV,D/C New Ranchi-New Purulia Line: CKT-2 | 26-09-2024 20:06 | 26-09-2024 20:16 | 0:00:00 | 0:00:00 | 0:00:00 | 0:10:00 | PGCIL taken the shutdown for taking back the Non-Switchable LR into service. Only Line portion under the ownership of PKTCL. | |
| 400 kV Chaibasa-Kharagpur D/C line CKT- 2 | | | 0:00:00 | 0:00:00 | 0:00:00 | 0:00:00 | No Outage/Tripping in this in the month of September 2024 | |
| 400 kV Chaibasa-Kharagpur D/C line CKT- 1 | | | 0:00:00 | 0:00:00 | 0:00:00 | 0:00:00 | No Outage/Tripping in this in the month of September 2024 | |

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of SEPTEMBER 2024

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |
| Nil | Nil | Nil |

III. Details of compensation paid by the inter-State transmission licensee for the month of SEPTEMBER 2024

Schedule III

| Element Name | Violation of Regulation | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|---------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |