

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV D/C Silchar-Misa Ckt 2	21/10/2024 09:09	21/10/2024 09:47	0:00	0:38	0:00	0:00	Line tripped from Misa end and A/R successful from Silchar end due to B-N fault at Silchar end and Y-N fault from Misa. Only Line Portion belongs to NER-IITL Shutdown code - Charging Code - 993	
400kV D/C Silchar-Misa Ckt 2	25/10/2024 11:24	25/10/2024 16:52	0:00	0:00	0:00	5:28	PGCIL Taken the emergency shutdown for attending Leakage of Main and Tie GIS CB at Silchar S/S Shutdown code - 1227 Charging Code - 1240	
132kV AGTTP(NEEPCO) - P.K.Bari Ckt-2	28/10/2024 08:59	28/10/2024 11:45	0:00	2:46	0:00	0:00	Line tripped due to B-phase to Earth fault from P.K. Bari end and was ideally charged from NEEPCO end. Shutdown code - Charging Code - 1360	
132kV AGTTP(NEEPCO) - P.K.Bari Ckt-1			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	
400kV D/C Silchar-Misa Ckt 1			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	
132kV Gohpur-Itanagar ckt-01			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	
132kV D/C Itanagar-BNC ckt-01			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	
132kV BNC-Gohpur ckt-01			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	
400kV Surajmaninagar- P.K.Bari Ckt-2			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	
400kV Surajmaninagar- P.K.Bari Ckt-1			0:00	0:00	0:00	0:00	NO Tripping / Outages in this month Shutdown code - Charging Code -	

**NER-II TL****II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCTOBER 2024****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of OCTOBER 2024****Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL

