

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of OCTOBER 2024

Schedule I

Element Name	Outage		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at Kadarpur(GPTL)	01-10-2024 00:00	01-11-2024 00:00	744:00	00:00	00:00	00:00	Bus Reactor could not be charged due to differential protection operated at 03:51 Hrs on 03-08-2024 against code: NRLDC-323. <b>Still not charged in this month.</b>	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	04-10-2024 10:12	04-10-2024 17:30	00:00	00:00	00:00	600:50	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Continuously in outage from last month.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	07-10-2024 09:48	11-10-2024 21:20	00:00	00:00	00:00	07:18	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	13-10-2024 09:54	13-10-2024 16:10	00:00	00:00	00:00	107:32	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	16-10-2024 11:29	16-10-2024 20:56	00:00	00:00	00:00	06:16	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	18-10-2024 10:54	22-10-2024 00:24	00:00	00:00	00:00	09:27	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	23-10-2024 09:53	24-10-2024 00:46	00:00	00:00	00:00	85:30	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	24-10-2024 09:16	25-10-2024 15:25	00:00	00:00	00:00	14:53	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	27-10-2024 11:13	27-10-2024 15:57	00:00	00:00	00:00	30:09	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	28-10-2024 08:57	30-10-2024 22:09	00:00	00:00	00:00	04:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	28-10-2024 08:56	28-10-2024 18:26	00:00	00:00	00:00	61:12	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	29-10-2024 09:44	30-10-2024 20:58	00:00	00:00	00:00	09:30	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	29-10-2024 09:44	30-10-2024 20:58	00:00	00:00	00:00	35:14	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	

**Gurgaon Palwal Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCTOBER 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of OCTOBER 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil

