

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of September 2024

Schedule I

| Element Name | Outage | Restoration | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|--|------------------|------------------|------------------------------------|---------|--|------------------|--|----------------|
| | Date Time | Date Time | Inter-State Transmission Licensee | Others | System constraint/ Natural calamity/ Militancy | Deemed Available | | |
| | | | Hrs:Min | Hrs:Min | Hrs:Min | Hrs:Min | | |
| 400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL) | 01-09-2024 00:00 | 01-10-2024 00:00 | 720:00 | 00:00 | 00:00 | 00:00 | Continuously in outage from previous month. Still not charged in this month. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 01-09-2024 00:00 | 14-09-2024 00:13 | 00:00 | 00:00 | 00:00 | 312:13 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. Continuously in outage from last month. | |
| 400KV,125MVAR Bus Reactor-1 at Prithala(GPTL) | 01-09-2024 00:00 | 13-09-2024 04:12 | 00:00 | 00:00 | 00:00 | 292:12 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. Continuously in outage from last month. | |
| 400KV,125MVAR Bus Reactor-1 at Prithala(GPTL) | 13-09-2024 11:31 | 14-09-2024 00:19 | 00:00 | 00:00 | 00:00 | 12:48 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 17-09-2024 10:23 | 19-09-2024 01:48 | 00:00 | 00:00 | 00:00 | 39:25 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400KV,125MVAR Bus Reactor-1 at Prithala(GPTL) | 17-09-2024 10:20 | 19-09-2024 01:51 | 00:00 | 00:00 | 00:00 | 39:31 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 21-09-2024 10:38 | 23-09-2024 18:08 | 00:00 | 00:00 | 00:00 | 55:30 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400KV,125MVAR Bus Reactor-1 at Prithala(GPTL) | 21-09-2024 10:45 | 01-10-2024 00:00 | 00:00 | 00:00 | 00:00 | 229:15 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 24-09-2024 09:41 | 25-09-2024 19:15 | 00:00 | 00:00 | 00:00 | 33:34 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |
| 400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL) | 30-09-2024 10:41 | 30-09-2024 17:57 | 00:00 | 00:00 | 00:00 | 07:16 | Bus reactor taken out as per NRLDC instructions due to voltage regulation. | |

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2024

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| NIL | NIL | NIL |
| NIL | NIL | NIL |

III. Details of compensation paid by the inter-State transmission licensee for the month of September 2024

Schedule III

| Element Name | Violation of Regulation | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|---------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |