

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of October 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Uri1(NHPC)-Amargarh(NRSS)-1	16/10/2024 14:41	16/10/2024 17:54	0:00	3:13	0:00	0:00	Line tripped due to Y-phase to earth fault. FL was 49.41Kms from Amargarh SS. Only 3.46 km is under the jurisdiction of NRSS-XXIX.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	18/10/2024 10:11	22/10/2024 01:45	0:00	0:00	0:00	87:34	NRSS-XXIX taken the Shutdown availed for AMP work.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	18/10/2024 10:11	22/10/2024 01:45	0:00	0:00	0:00	87:34	Shutdown availed by RTAMC-Jammu for Line equipment AMP work at Sambha SS.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	22/10/2024 10:03	22/10/2024 21:39	0:00	0:00	0:00	11:36	Shutdown availed by RTAMC-Jammu for Line equipment AMP work at Sambha SS.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	22/10/2024 10:03	22/10/2024 21:39	0:00	0:00	0:00	11:36	Continuously in outage from July'24 month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	23/10/2024 09:49	31/10/2024 22:09	0:00	0:00	0:00	204:20	Continuously in outage from July'24 month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	23/10/2024 09:49	31/10/2024 22:09	0:00	0:00	0:00	204:20	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	

**NRSS-XXIX Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCTOBER 2024**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of OCTOBER 2024**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL

