

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of September 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400KV Patiala-Patran-1	04/09/2024 04:13	04/09/2024 16:52	0:00	12:39	0:00	0:00	Line tripped due to B-phase to Earth fault, FL is 47.2Kms and FC is 5.5KA, Charging attempt failed at 05:22 Hrs from PTCL(Patran). Only 100 Mtr is under the Ownership of PTCL.	

Patran Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of September 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL