

Parbati Koldam Transmission Company Limited

I. AC Transmission Line Outage Details for the month of September 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time		Date Time		Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Koldam-Ludhiana Ckt 1	27/09/2024	19:07	27/09/2024	20:58	1:51	0:00	0:00	0:00	Emergency shutdown availed to remove stuck rope from tower no 407	
400 KV Parbati_2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	09/09/2024	10:24	09/09/2024	17:12	0:00	0:00	0:00	6:48	Shutdown availed by Parbati-2 HEP for relay testing work.	
400 KV Parbati_2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	10/09/2024	10:23	10/09/2024	18:41	0:00	0:00	0:00	8:18	Shutdown availed by Parbati-2 HEP for relay testing work.	
400 KV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt-1	11/09/2024	10:03	11/09/2024	19:11	0:00	0:00	0:00	9:08	Shutdown availed by Parbati-2 HEP for relay testing work.	
400 KV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt-1	12/09/2024	10:05	12/09/2024	17:05	0:00	0:00	0:00	7:00	Shutdown availed by Parbati-2 HEP for relay testing work.	
400 KV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt-1	14/09/2024	09:45	14/09/2024	19:44	0:00	0:00	0:00	9:59	Shutdown availed by Parbati-2 HEP for testing of bus bar relay protection of Parbati-II HE Project	
400 KV Parbati_2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	14/09/2024	09:43	14/09/2024	19:42	0:00	0:00	0:00	9:59	Shutdown availed by Parbati-2 HEP for testing of bus bar relay protection of Parbati-II HE Project	
400 KV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt-1	15/09/2024	09:13	15/09/2024	20:20	0:00	0:00	0:00	11:07	Shutdown availed by Parbati-2 HEP for testing of bus bar relay protection of Parbati-II HE Project	
400 KV Parbati_2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	15/09/2024	09:14	15/09/2024	19:58	0:00	0:00	0:00	10:44	Shutdown availed by Parbati-2 HEP for testing of bus bar relay protection of Parbati-II HE Project	
400 KV Parbati_2(NH)-Parbati Pooling Banala(PG) (PKTCL) Ckt-1	16/09/2024	09:40	16/09/2024	18:05	0:00	0:00	0:00	8:25	Shutdown availed by Parbati-2 HEP for testing of bus bar relay protection of Parbati-II HE Project	
400 KV Parbati_2(NH)-Sainj(HP) (PKTCL) Ckt-1	16/09/2024	09:37	16/09/2024	18:26	0:00	0:00	0:00	8:49	Shutdown availed by Parbati-2 HEP for testing of bus bar relay protection of Parbati-II HE Project	

Parbati Koldam Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of September 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL