

Maheshwaram Transmission Limited

I. AC Transmission Line Outage Details for the month of OCTOBER 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400kV Nizamabad(PG)-Shankarapally(TS) Line-2	14-10-2024	16:42:00	14-10-2024	19:59:00	3:17:00	0:00:00	0:00:00	0:00:00	Line tripped due to R-ph to Earth. Shutdown Code - Charging Code - 1405	99.87%
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-1	22-10-2024	10:05:00	22-10-2024	18:27:00	0:00:00	0:00:00	0:00:00	8:22:00	PGCIL taken the shutdown for AMP work of terminal Bay equipment at PGCIL Maheshwaram SS. Shutdown Code - 2185 Charging Code - 2267	
400kV Maheshwaram(PG)-Mehboob nagar(TS) Line-2					0:00:00	0:00:00	0:00:00	0:00:00	No Tripping / outage for the month of OCTOBER-24.	
400kV Nizamabad(PG)-Shankarapally(TS) Line-1					0:00:00	0:00:00	0:00:00	0:00:00	No Tripping / outage for the month of OCTOBER-24.	

Maheshwaram Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCTOBER 2024

Schedule II

I. AC Transmission Line Outage Details for the month of OCTOBER 2024

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of OCTOBER 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil