

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of OCT 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I	07-10-2024	10:30:00	07-10-2024	18:18:00	0:00	7:48	0:00	0:00	MPPTCL taken the Shutdown For bay maintenance testing work.	
765 KV Bus Reactor at BDTCL Dhule	08-10-2024	09:51:00	08-10-2024	20:09:00	0:00	0:00	0:00	10:18	BR Hand Trip as per RLDC Instruction due to Voltage Regulation	
765KV S/C Aurangabad-Dhule Line	09-10-2024	17:01:00	09-10-2024	17:01:00	0:00	0:00	0:00	0:00	AR Successful due to transient B-phase to Earth Fault. Aurangabad End: M1-172.4km, 4.9kA; M2 - 171.3km, 4.3kA Dhule End: M1-3.08km, 11.11kA; M2 - 0km, 0kA	
765kV Dhule(BDTCL) - Vadodara(PG)	09-10-2024	20:59:00	10-10-2024	08:52:00	11:53	0:00	0:00	0:00	Line tripped due to B-phase to Earth Fault. Vadodara End: M1-57.30km, 7.09kA; M2 - 0km, 0kA Dhule End: M1-185.6km, 3.58kA; M2 - 185.5km, 3.71kA	
765 kv bus reactor at BDTCL Bhopal	14-10-2024	07:29:00	16-10-2024	21:56:00	0:00	0:00	0:00	62:27	BR Hand Trip as per RLDC Instruction due to Voltage Regulation	
765 KV Bus Reactor at BDTCL Dhule	16-10-2024	09:52:00	17-10-2024	03:16:00	0:00	0:00	0:00	17:24	BR Hand Trip as per RLDC Instruction due to Voltage Regulation	
765 KV Bus Reactor at BDTCL Dhule	24-10-2024	17:11:00	27-10-2024	13:33:00	0:00	0:00	0:00	68:22	BR Hand Trip as per RLDC Instruction due to Voltage Regulation	
765 KV Bus Reactor at BDTCL Dhule	28-10-2024	09:56:00	31-10-2024	13:40:00	0:00	0:00	0:00	75:44	BR Hand Trip as per RLDC Instruction due to Voltage Regulation	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
400 KV Bus Reactor at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765/400 KV ICT 1 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765/400 KV ICT 2 at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
BHOPAL-INDORE 765 KV LINE					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765 kV Bhopal-Jabalpur LR at Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765 KV Indore LR at BDTCL Bhopal					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765/400 KV ICT 1 at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765/400 KV ICT 2 at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765 KV Vadodara Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765 KV Aurangabad Line Reactor at BDTCL Dhule					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line					0:00	0:00	0:00	0:00	No Tripping/ outages for the month of OCT24	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Oct 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of Oct 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil