

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of SEP 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400 KV Bus Reactor at BDTCL Bhopal	09-04-2024	9:56:00 AM	09-04-2024	5:01:00 PM	07:05	00:00	00:00	00:00	Planned Shutdown	
765/400 KV ICT 1 at BDTCL Bhopal	09-05-2024	9:51:00 AM	09-05-2024	9:24:00 PM	11:33	00:00	00:00	00:00	Planned Shutdown	
765/400 KV ICT 2 at BDTCL Bhopal	09-06-2024	9:48:00 AM	09-06-2024	7:33:00 PM	09:45	00:00	00:00	00:00	Planned Shutdown	
765kV Dhule(BDTCL) - Vadodara(PG)	09-10-2024	4:48:00 AM	09-10-2024	4:48:00 AM	00:00	00:00	00:00	00:00	AR Successful. R-phase to Earth Fault Dhule End: M1- 189.2km, 3.465kA; M2 - 0km, 0kA Vadodara End: M1 - 54.3km, 7.23kA; M2 - 54.4km, 7.2kA	
765 KV S/C Bhopal(BDTCL) Jabalpur(PGCIL) Line	09-10-2024	7:15:00 AM	09-10-2024	3:35:00 PM	08:20	00:00	00:00	00:00	Tripped because of Insulator Failure B-phase to Earth Fault Bhopal End: M1- 13.2km, 8.37kA; M2 - 13.3km, 8.3kA Jabalpur End: M1 - 221km, 4.1kA; M2 - 224.8km, 4.1kA	
765 kV Bhopal-Jabalpur LR at Bhopal	09-10-2024	2:35:00 PM	09-10-2024	3:35:00 PM	01:00	00:00	00:00	00:00	Emergency Shutdown. Spare Phase of Line reactor CB which was in service was reflecting Intermediate stage in SCADA, so we switched it and taken RYB phase into service.	
765 KV Bus Reactor at BDTCL Dhule	9/23/2024	9:41:00 AM	9/23/2024	10:09:00 PM	00:00	00:00	12:28	00:00	Due to Voltage Regulation	
765 kv bus reactor at BDTCL Bhopal	9/23/2024	6:58:00 AM	9/26/2024	10:43:00 PM	00:00	00:00	87:45:00	00:00	Due to Voltage Regulation	
765 KV Bus Reactor at BDTCL Dhule	9/25/2024	9:57:00 AM	9/26/2024	10:24:00 PM	00:00	00:00	36:27:00	00:00	Due to Voltage Regulation	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) II					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765/400 KV ICT 1 at BDTCL Bhopal					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765/400 KV ICT 2 at BDTCL Bhopal					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL) I					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
BHOPAL-INDORE 765 KV LINE					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765 KV Indore LR at BDTCL Bhopal					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765KV S/C Aurangabad-Dhule Line					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765/400 KV ICT 1 at BDTCL Dhule					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765/400 KV ICT 2 at BDTCL Dhule					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-1					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
400KV Dhule(BDTCL)-Dhule MSETCL CKT-2					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765 KV Vadodara Line Reactor at BDTCL Dhule					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	
765 KV Aurangabad Line Reactor at BDTCL Dhule					00:00	00:00	00:00	00:00	No Tripping/ outages for the month of SEP24	

Bhopal Dhule Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of Sep 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of Sep 2024

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil